

CLIENT INFORMATION

Name: Chatham Central School District
SCHOOL/PROJECT INFO WATER TESTING
BLDG ADDRESS:
CONTACT NAME & NUMBERS: Steve Nieto (518) 392-1525

Updated 10/10/2018

Legend

F

DW

I

Faucet

Drinking Water

Ice Machine

SAMPLE DATA

Sample Description ID (ID must match container label)

Lab Sample #	Chatham CSD Sample #	Location	Outlet Description	First Draw	Sample Time	Lead @ .015	Lead @ .016 & >	Retest after Remediation
MED ELEMENTARY SCHOOL								
1	MED-F-1	Kitchen	Food Prep	x	5:28	0.001		
2	MED-F-2	Kitchen	Food Prep	x	5:27	0.008		
3	MED-F-3	Kitchen	Food Prep	x	5:26	0.014		
4	MED-F-4	Kitchen	Hand Wash Only/ Signage	x	5:23		0.017	
5	MED-F-5	Kitchen	Hand Wash Only	x	5:24	0.015		
6	MED-F-6	Kitchen	Food Prep	x	5:28	0.007		
7	MED-F-7	Kitchen	Dish Wash Spray	x	5:28	0.002		
8	MED-F-8	Kitchen	Food Prep	x	5:29		0.021	0.003
9	MED-DW-9	Café		x	5:31	0.001		
10	MED-DW-10	room211		x	7:25		0.02	0.007
11	MED-F-11	room211		x	7:25	0.010		0.005
12	MED-DW-12	room212		x	7:21	0.015		0.004
13	MED-F-13	room212		x	7:21		0.016	0.005
14	MED-DW-14	room213		x	7:20	0.005		
15	MED-F-15	room213		x	7:20	0.015		
16	MED-DW-16	room214		x	7:19	0.012		
17	MED-F-17	room214		x	7:19	0.008		
18	MED-DW-18	room215		x	7:10	0.012		
19	MED-F-19/135	room215	Not Running	x		0.013		
20	MED-F-20	Library		x	5:35		0.032	0.014
21	MED-F-21	Girls Bath/Library		x	5:36	0.003		
22	MED-F-22	Boys Bath/Library		x	5:36	0.003		
23	MED-F-23	Mens/Lobby		x	5:38		0.034	0.005
24	MED-F-24	Mens/Lobby		x	5:38	0.013		
25	MED-F-25	Ladies Bath/Lobby		x	5:40	0.007		
26	MED-F-26	Ladies Bath/Lobby		x	5:40	0.007		
27	MED-DW-27	Lobby Drinking Fountain		x	5:37	0.008		
28	MED-F-28	Custodial		x	5:41	0.010		
29	MED-F-29	Room218		x	5:42	0.003		
30	MED-DW-30	Room218		x	5:42	0.003		
31	MED-F-31	Room232		x	5:44	0.004		
32	MED-DW-32	Room232		x	5:44	0.003		
33	MED-DW-33	Room 231		x	5:44	0.002		
34	MED-F-34	Room231		x	5:46	0.005		
35	MED-F-35	Room 219		x	5:46	0.003		
36	MED-DW-36	Room 219		x	5:46	0.003		
37	MED-F-37	Room220		x	5:49	0.008		
38	MED-DW-38	Room220		x	5:49	0.007		
39	MED-F-39	Room230		x	5:48	0.014		
40	MED-F-40	Room229		x	5:52		0.046	0.004
41	MED-DW-41	Hallway/221		x	5:55	0.001		
42	MED-DW-42	Room 221		x	5:54	0.002		
43	MED-F-43	Room221		x	5:54	0.002		
44	MED-F-44	Room221		x	5:53	0.015		
45	MED-DW-45	Room222		x	6:01	0.003		
46	MED-F-46	Room222		x	6:01	0.014		
47	MED-DW-47	Room228		x	6:05	0.002		
48	MED-F-48	Room228		x	6:05	0.005		
49	MED-F-49	room224		x	6:09	0.003		
50	MED-DW-50	room224		x	6:09	0.002		
51	MED-DW-51	Room227		x	6:06	0.003		
52	MED-F-52	Room227		x	6:06	0.004		
53	MED-F-53	Room226		x	6:10	0.005		0.001

54	MED-DW-54	Room226		x	6:10	0.002		
55	MED-F-55	Room225		x	6:11	0.005		
56	MED-DW-56	Room225		x	6:11	0.006		
57	MED-F-57	Supt. Conf. Bath		x	6:14		0.024	0.015
58	MED-F-58	Faculty		x	6:20	0.014		
59	MED-F-59	Faculty		x	6:20	0.006		
60	MED-F-60	Nurse		x	6:16	0.004		
61	MED-F-61	Nurse		x	6:17	0.009		
62	MED-NI-62	Nurse Ice Machine		x	6:17	0.005		
63	MED-DW-63	Hallway/Gym		x	6:25	0.003		
64	MED-F-64	Girls Locker		x	6:24	0.008		
65	MED-F-65	Girls Bath/302		x	6:27		0.018	0.001
66	MED-F-66	Girls Bath/302		x	6:27	0.009		
67	MED-F-67	Boys Bath/302		x	6:28		0.016	0.001
68	MED-F-68	Boys Bath/302		x	6:28		0.025	0.001
69	MED-DW-69	Room303		x	6:28	0.011		
70	MED-F-70	Room303		x	6:30	0.013		
71	MED-DW-71	Room317		x	6:31		0.016	0.003
72	MED-F-72	Room317		x	6:31	0.006		0.002
73	MED-F-73	room304		x	6:33	0.008		
74	MED-DW-74	room304		x	6:33	0.009		
75	MED-DW-75	room316		x	6:34	0.007		
76	MED-F-76	room316		x	6:34	0.005		
77	MED-F-77	room305		x	6:39		0.024	0.006
78	MED -DW -78	room305		x	6:40		0.031	0.015
79	MED-F-79	room306		x	6:40	0.008		0.006
80	MED-DW-80	room306		x	6:41	0.014		
81	MED-F-81	room313		x	6:41			0.011
	MED F-81-2	room 313	2nd draw			0.002		
82	MED-DW-82	room313		x	6:36		0.023	0.004
83	MED-DW-83	Hallway/88 wing		x	6:36	<.001		
84	MED-DW-84	Hallway/88 wing		x	6:38	<.001		
85	MED-F-85	Girls Bath/88 wing		x	6:38	0.013		
86	MED-F-86	Girls Bath/88 wing		x	6:37	0.011		
87	MED-F-87	Boys Bath/88 wing		x	6:37		0.022	0.001
88	MED-F-88	Boys Bath/88 wing		x	6:37	0.01		
89	MED-F-89/140	room307		x	6:44		0.024	0.006
	MED -F-89-2	room 307	2nd draw			0.002		
90	MED-DW-90	room307		x	6:44	0.006		
91	MED-F-91	room312		x	6:43		0.02	0.005
92	MED-DW-92	room312		x	6:43	0.012		0.014
93	MED-DW-93	room311		x	6:48	0.004		
94	MED-F-94	room311		x	6:48	0.002		
95	MED-DW-95	room308		x	6:47	0.005		
96	MED-F-96	room308		x	6:47	0.007		
97	MED-F-97	room310		x	6:50		0.016	0.001
98	MED-DW-98	room310		x	6:50	0.009		
99	MED-DW-99	room309		x	6:49	0.003		
100	MED-F-100	room309		x	6:49		0.017	0.006
101	MED-F-101	room101		x	7:39		0.018	0.008
102	MED-F-102	room101		x	7:39	0.007		0.005
103	MED-F-103	room102		x	7:40	0.011		
104	MED-DW-104	room102		x	7:40	0.001		
105	MED-F-105	room103		x	7:41	0.007		
106	MED-F-106	DS/Hall Bathroom		x	6:00	0.002		
107	MED-F-107	room104		x	10:03		0.018	0.003
108	MED-F-108	room105		x	7:46		0.016	0.008
109	MED-F-109	room106		x	7:46	0.010		
110	MED-F-110	room107		x	7:47		0.022	0.005
111	MED-F-111	room108		x	7:48	0.015		
112	MED-DW-112	Hallway/downstairs		x	7:43	0.010		
113	MED-F-113	Boys Bath/229		x	5:59	0.009		
114	MED-F-114	Boys Bath/229		x	5:59	0.008		
115	MED-F-115	Boys Bath/229		x	5:59	0.013		

116	MED-F-116	Boys Bath/229		x	5:59		0.05	0.007
117	MED-F-117	Girls Bath/229		x	5:57	0.002		
118	MED-F-118	Girls Bath/229		x	5:57	0.003		
119	MED-F-119	Girls Bath/229		x	5:57	0.002		
120	MED-F-120	Girls Bath/229		x	5:57	0.003		
121	MED-F-121	Main Office Sink		x	6:49	0.004		
122	MED-F-122/139	310		x	6:44	0.002		0.001
123	MED-F-123	307		x	6:44	0.002		
124	MED-F-124	Downstairs Hall		x	7:42	0.006		
125	N/A							
126	MED-F-126	212-F-Bathroom		x	7:42		0.021	0.014
127	MED-F-127	211-F-Bathroom		x	7:25	0.013		
128	MED-DW-128	223		x	6:03	0.001		
129	MED-F-129	223		x	6:03	0.006		
130	MED-F-130	Art		x	6:57	0.004		
131	MED-F-131	Art		x	7:51	0.015		0.004
132	MED-F-132/135	229				0.015		
133	MED-F-133	229		x	7:36		0.018	0.004
134	MED-F-134	220		x	7:35	0.006		
135	MED-F-135	215		x		0.015		0.003
139	MED-F-139/122	310				0.001		
140	MED-F-140/89					0.15		0.006
MIDDLE SCHOOL								
1	MS-F-1	GA2/Technology	lab-signage	x	9:54		0.018	
2	MS-F-2	GA1		x	9:52	0.014		
3	MS-DW-3	GA1		x	9:51	0.008		
4	MS-F-4	GA3		x	9:53	0.012		
5	MS-DW-5	GA3		x	9:52	0.004		
6	MS-DW-6	Hallway/GA6	removed	x	9:55			
7	MS-F-7	Public Library/conf.		x	10:00	0.006		
8	MS-F-8	Public Library/grd. Floor		x	10:00	0.005		
9	MS-DW-9	Public Library/Lobby		x	10:02	0.003		
10	MS-F-10	GB2		x	10:07	0.006		
11	MS-DW-11	GB2		x	10:07	0.003		
12	MS-F-12	GB1		x	10:09	0.005		
13	MS-DW-13	GB1		x	10:08	0.005		
14	MS-F-14	GB4		x	10:11	0.007		
15	MS-DW-15	GB4		x	10:12	0.006		
16	MS-F-16	GB6		x	10:13	0.005		
17	MS-DW-17	GB6		x	10:13	0.003		
18	MS-F-18	GB8		x	10:15	0.005		
19								
20	MS-F-20	GB5		x	10:16	0.004		
21	MS-DW-21	GB5		x	10:17	0.002		
22	MS-DW-22	Hallway/GB4		x	10:10	0.005		
23	MS-DW-23	Hallway/GB4		x	10:10	0.005		
24	MS-DW-24-134	Boys Locker		x	10:02		0.02	0.001
25	MS-F-25	Boys Locker		x	10:02		0.056	0.008
26	MS-F-26	Boys Locker		x	10:03	0.006		
27	MS-F-27	Kitchen Bath		x	10:00	0.013		
28	MS-F-28	Kitchen	Food Prep	x	9:53	0.008		
29	MS-F-29	Kitchen	Hand Wash Only	x	9:53		0.021	0.007
30	MS-F-30	Kitchen	Food Prep	x	10:03	0.013		0.001
31	MS-F-31	Kitchen	Food Prep	x	9:54		0.016	0.001
32	MS-I-32	Kitchen Ice Machine		x	9:58	<0.001		
33	MS-F-33	Band Office		x	9:51	0.012		
34	MS-F-34	Boys Bath/Gym		x	9:56	0.015		0.005
35	MS-F-35	Boys Bath/Gym		x	9:50		0.028	0.008
36	MS-F-36	Girls Bath/Gym		x	9:49		0.02	0.006
37	MS-F-37	Girls Bath/Gym		x	9:49		0.024	0.007
38	MS-F-38	Custodial Office		x	10:40	0.012		
39	MS-DW-39	Custodial Office		x	10:40	0.007		
40	MS-DW-40	Hallway/Gym		x	9:48	0.003		
41	MS-F-41	Bathroom/Library		x	10:05	0.011		
42	MS-F-42	Copy/Library		x	10:04	0.002		

43	MS-F-43	1A1		x	10:21		0.016	0.001
44	MS-F-44	1A1		x	10:22		0.025	0.003
45				x				
46	MS-F-46	1B2		x	10:32	0.012		
47	MS-F-47	1B2		x	10:33	0.012		
48	MS-F-48	1B2	lab-signage	x	10:33		0.028	
49	MS-F-49	1B2	lab-signage	x	10:34		0.024	
50	MS-F-50	1B2	lab-signage	x	10:34		0.034	
51								
52								
53								
54	MS-F-54	1B8	lab-signage	x	10:39		0.140	
55	MS-F-55	1B8	lab-signage	x	10:39		0.033	
56	MS-F-56	1B8	lab-signage	x	10:38		0.021	
57	MS-F-57	1B8	lab-signage	x	10:38		0.05	
58	MS-F-58	1B8	lab	x	10:38	0.008		
59	MS-DW-59	Hallway/1B4		x	10:35		0.017	0.004
60	MS-DW-60	Hallway/1B4		x	10:35		0.02	0.009
61	MS-F-61	Main Office		x	10:08	0.006		
62	MS-F-62	1C7/NurseBathroom		x	10:13	0.015		0.012
63	MS-F-63	1C7 Nurse		x	10:09	0.013		
64	MS-F-64	1C7 Nurse		x	10:09	0.008		
65	MS-NI-65	1C7 Nurse		x	10:11	>0.001		
66	MS-DW-66	Hallway/1C7		x	10:12	0.004		
67	MS-DW-67	Hallway/1C7		x	10:12	0.004		
68	MS-DW-68	Girls Locker		x			0.028	0.007
69	MS-F-69	Girls Locker		x	10:05		0.048	0.012
70	MS-F-70	Girls Locker		x	10:05	0.009		
71	MS-F-71	Girls Locker		x	10:05		0.034	0.002
72	MS-F-72	Faculty		x	10:30	0.002		
73	MS-F-73	2A2		x	10:28	0.013		
74	MS-DW-74	2A2		x	10:29	0.006		
75	MS-F-75	2A1		x	10:26		0.027	0.007
76	MS-F-76	2A1		x	10:27		0.027	0.006
77	MS-F-77	2A1		x	10:27	0.006		
78	MS-F-78	2A1		x	10:29	0.008		
79	MS-F-79	Mens/Faculty		x	10:30		0.075	0.012
80	MS-F-80	Womens/Faculty		x	10:31	0.012		0.005
81	MS-F-81	2B2	lab-signage	x	10:31		0.065	
82	MS-F-82	2B2	lab-signage	x	10:31		0.14	
83	MS-F-83	2B2	lab-signage	x	10:32		0.038	
84	MS-F-84	2B2	lab-signage	x	10:32		0.053	
85	MS-F-85	2B2	lab-signage	x	10:32		0.03	
86	MS-F-86	2B2	lab-signage	x	10:32		0.058	
87	MS-F-87	2B2	lab-signage	x	10:33		0.034	
88	MS-F-88	2B2	lab-signage	x	10:33		0.048	
89	MS-F-89	2B2	lab-signage	x	10:33		0.024	
90	MS-F-90	2B2	lab-signage	x	10:33		0.045	
91	MS-F-91	2B2	lab-signage	x	10:35		0.029	
92	MS-F-92	2B2	lab-signage	x	10:35		0.064	
93								
94								
95	MS-DW-95	hallway/2B4		x	10:30	0.002		
96	MS-DW-96	hallway/2B4		x	10:30	0.003		
97	MS-F-97	2B8	lab-signage	x	10:24		0.046	
98	MS-F-98	2B8	lab-signage	x	10:24		0.048	
99	MS-F-99	2B8	lab-signage	x	10:25		0.086	
100	MS-F-100	2B8	lab-signage	x	10:25		0.053	
101	MS-F-101	2B8	lab-signage	x	10:28		0.042	
102	MS-F-102	2B8	lab-signage	x	10:28		0.041	
103	MS-F-103	2B8	lab-signage	x	10:26		0.066	
104	MS-F-104	2B8	lab-signage	x	10:26		0.056	
105	MS-F-105	2C3	lab-signage	x	10:17		0.087	
106	MS-F-106	2C3	lab-signage	x	10:17		0.12	
107	MS-F-107	2C3	lab-signage	x	10:17		0.04	

108	MS-F-108	2C3	lab-signage	x	10:17		0.041	
109	MS-F-109	2C3	lab-signage	x	10:18		0.021	
110	MS-F-110	2C3	lab-signage	x	10:18		0.11	
111	MS-F-111	2C3	lab-signage	x	10:18		0.04	
112	MS-F-112	2C3	lab-signage	x	10:18		0.084	
113	MS-F-113	2C3	lab-signage	x	10:20		0.052	
114	MS-F-114	2C3	lab-signage	x	10:20		0.15	
115	MS-F-115	2C3	lab	x	10:20		0.04	0.007
116	MS-F-116	2C3	lab-signage	x	10:20		0.25	
117	MS-F-117	2C3	lab-signage	x	10:21		0.06	
118	MS-F-118	2C6		x	10:15	0.010		
119	MS-DW-119	Hallway/2C4		x	10:22	0.009		
120	MS-DW-120	Hallway/2C4		x	10:22	0.015		0.001
121/62	MS-F-1C7	Nurse Bath		x	10:10	0.004		
122	MS-F-122	Kitchen Pedal	Removed					
123	MS-F-123	Art		x	10:23	0.006		
124	MS-F-124	Art		x	10:23	0.009		
125	MS-F-125	Art		x	10:23	0.008		
126	MS-F-126	Art		x	10:24	0.010		
127	MS-F-127	Art		x	10:24	0.007		
128	MS-F-128	Art		x	10:25	0.006		
129	MS-F-129	2B2-F/Science	lab-signage	x	10:37		0.079	
130	MS-F-130	Kitchen	Food Prep	*		0.001		
131	MS-F-131	Faculty Kitchen Sink					0.016	0.009
132	MS-F-132	2A2 Bathroom				0.01		
133	MS-F-133	Kitch Serv Spicket					0.098	0.015
134	MS-DWF-134-24	Boys Locker Room					0.02	0.001
135	MS-DW-135	Cafe				0.001		
HIGH SCHOOL								
1	HS-F-1	room 120	lab-signage	x	8:12		0.027	
2	HS-F-2	room 120	lab-signage	x	8:13		0.021	
3	HS-F-3	room 121	lab-signage	x	8:17		0.039	
4	HS-F-4	room121	lab-signage	x	8:17		0.045	
5	HS-F-5	room121	lab	x	8:18	0.010		
6	HS-F-6	room121	lab	x	8:19	0.006		
7	HS-F-7	room121	lab	x	8:19	0.012		
8	HS-F-8	room121	lab	x	8:19	0.009		
9	HS-F-9	room121	lab	x	8:20	0.003		
10	HS-F-10	room122	lab-signage	x	8:22		0.26	
11	HS-F-11	room122	lab-signage	x	8:23		0.017	
12	HS-F-12	room122	lab-signage	x	8:24		0.018	
13	HS-F-13	room123	lab-signage	x	8:29		0.073	
14	HS-F-14	room123	lab-signage	x	8:28		0.061	
15	HS-F-15	room123	lab-signage	x	8:28		0.032	
16	HS-F-16	124A	lab-signage	x	8:34		0.067	
17	HS-F-17	room125	lab	x	8:39	0.005		
18	HS-F-18	room125	lab-signage	x	8:38		0.021	
19	HS-F-19	room125	lab-signage	x	8:38		0.043	
20	HS-F-20	room126	lab-signage	x	8:41		0.037	
21	HS-F-21	room126	lab-signage	x	8:41		0.017	
22	HS-F-22	room126	lab-signage	x	8:42		0.026	
23	HS-F-23	room126	lab-signage	x	8:42		0.019	
24	HS-F-24	room126	lab-signage	x	8:42		0.02	
25	HS-F-25	room 126	lab	x	8:43	0.014		
26	HS-F-26	room 126	lab-signage	x	8:44		0.034	
27	HS-F-27	room 126	lab-signage	x	8:44		0.021	
28	HS-F-28	room126	lab-signage	x	8:45		0.03	
29	HS-F-29	room126	lab-signage	x	8:45		0.016	
30	HS-F-30	room126	lab	x	8:45		0.032	0.007
31	HS-F-31	room126	lab	x	8:46		0.022	0.010
32								
33	HS-F-33	room126A	lab-signage	x	8:47		0.074	
34	HS-F-34	room127	lab-signage	x	8:51		0.022	
35	HS-F-35	room127	lab-signage	x	8:52		0.024	
36	HS-F-36	room127	lab-signage	x	8:52		0.046	

37	HS-F-37	room127	lab-signage	x	8:53		0.06	
38	HS-F-38	Boys Bath/128		x	8:49		0.021	0.006
39	HS-F-39	Boys Bath/128		x	8:49		0.016	0.008
40	HS-F-40	Girls Bath/128		x	8:50		0.017	0.007
41	HS-F-41	Girls Bath/128		x	8:50		0.027	0.006
42	HS-F-42	Girls Bath/128		x	8:50		0.032	0.002
43	HS-DW-43	Hallway128/water fountain		x	8:48	0.007		
44				x				
45	HS-DW-45	Hallway cust./water fountain		x	8:16		0.043	0.001
46	HS-DW-46	Hallway cust./water fountain		x	8:16		0.066	0.014
47	HS-DW-47	Custodian Drinking Fountain		x	8:15	0.002		
48	HS-F-48	Custodian Room		x	8:15	0.012		
49	HS-F-49	Kitchen	Food Prep	x	8:40		0.024	0.001
50	HS-F-50	Kitchen	Food Prep	x	8:40		0.024	0.002
51	HS-F-51	Kitchen	Food Prep	x	8:40		0.018	0.001
52	HS-F-52	Kitchen	Hand Wash Only	x	8:39		0.025	0.01
53	HS-F-53	Kitchen	Hand Wash Only	x	8:39		0.031	0.007
54	HS-F-54	Faculty		x	8:42	0.002		
55	HS-F-55	room107		x	8:35		0.052	0.010
56	HS-F-56	room107		x	8:35		0.023	0.007
57	HS-F-57	room107		x	8:35		0.034	0.009
58	HS-F-58	room105	Signage	x	8:34		0.038	0.03
59	HS-F-59	Boys Bath/104		x	8:33		0.036	0.010
60	HS-F-60	Boys Bath/104		x	8:33	0.008		
61	HS-F-61	Boys Bath/104		x	8:33	0.009		
62	HS-F-62	Girls Bath/104		x	8:31	0.013		
63	HS-F-63	Girls Bath/104		x	8:31	0.009		
64	HS-F-64	Girls Bath/104		x	8:31	0.009		
65	HS-DW-65	Hallway 104		x	8:30	0.009		
66	HS-DW-66	Hallway 104		x	8:30	0.004		
67	HS-F-67	Library	Signage	x	8:30		0.045	0.14
68	HS-F-68	Library	Signage	x	8:29		0.08	0.24
69	HS-F-69	Main Office/Bathroom		x	8:27		0.026	0.012
70	HS-F-70	Mens Bath Lobby		x	8:24	0.008		
71	HS-F-71	Womens Bath Lobby		x	8:24	0.005		
72	HS-DW-72	Lobby		x	8:24	<0.001		
73	HS-F-73	Nurse		x	8:22	0.015		
74	HS-F-74	Nurse		x	8:22	0.009		
75	HS-F-75	Boys Bath/Gym Hall		x	8:23	0.005		
76	HS-F-76	Girls Bath/Gym Hall		x	8:18	0.006		
77	HS-DW-77	Gym Hall		x	8:19	<0.001		
78	HS-DW-78	Gym Hall		x	8:19	<0.001		
79	HS-I-79	Mech. Room/Ice Machine		x	8:21	0.012		
80	HS-F-80	Girls Locker		x	8:18	0.002		
81	HS-DW-81	Girls Locker	Disconnected					
82	HS-F-82	Boys Locker		x	8:16	0.011		
83	HS-DW-83	Boys Locker		x	8:16		0.026	0.008
84	HS-F-84	Room124	lab-signage	x	8:32		0.034	
85	HS-F-85	Room124	lab-signage	x	8:32		0.024	
86	HS-F-86	Room124	lab-signage	x	8:32		0.02	
87	HS-F-87	Room124	lab-signage	x	8:33		0.018	
88	HS-F-88	Room 107		x	8:35		0.028	0.005
89	HS-F-89	Room 121		x	8:20	0.014		
90	HS-F-90	Room 123	lab-signage	x	8:26		0.029	
91	HS-F-91	Room 123	lab-signage	x	8:27		0.028	
92	HS-F-92	Room 124	lab-signage	x	8:31		0.028	
93	HS-F-93	Room 124A	lab-signage	x	8:34		0.16	
94	HS-F-94	Room 125	lab-signage	x	8:36		0.037	
95	HS-F-95	Room 125	lab-signage	x	8:37		0.032	
96	HS-F-96	Band Room		x	8:14		0.032	0.010
97	HS-F-97	Dishwasher		x	8:37	0.005		
98	HS-F-98	Mens Fac		x	8:42	0.014		
99	HS-F-99	Womens Fac		x	8:43		0.017	0.005
100	HS-F-100	Main Office		x	8:27		0.027	0.005
	HS F-100-2	Main Office	Second Draw			0.002		

101	HS-F-101	Room 123A	lab-signage	x	8:58	0.053	
BUS GARAGE							
1	BG-F-1	Al's Bathroom		x	5:15	0.005	
2	BG-F-2	Womens/Breakroom		x	5:13	0.013	
3	BG-F-3	Mens/Breakroom		x	5:12	0.014	
4	BG-F-4	Breakroom		x	5:11	0.009	
5	BG-DW-5	Breakroom		x	5:10	0.006	
6	BG-F-6	Maint./Bathroom		x	5:08	0.013	
7	BG-F-7	Maint./Shop		x	5:07	0.008	
8	BG-DW-8	Maint./Shop		x	5:06	0.007	

10/10/2018 update
PP/SN